

IECEX/ANZEx Equipment Selection Chart

HAZARDOUS ZONES

ZONE Classification	Protection Method	Kinyun LED Lamp Ex Code
ZONE 0 Flammable atmosphere continuously present, or present for long periods (more than 1,000 hours per year.)	Ex ia: Intrinsically safe with two faults Ex s: Special protection (approved for Zone 0)	<p>Ex ia IIC T3 IP67 Intrinsically safe with two faults</p> <p>It covers all zones</p>
ZONE 1 Flammable atmosphere likely occur in normal operation (more than 10 hours per year, but less than 1,000 hours per year)	Ex d: Flameproof Ex ib: Intrinsically safe with one fault Ex p: Pressurization for Zone 1 Ex p1: Purging for Zone 1 Ex m: Encapsulation Ex e: Increased safety Ex v: Ventilation Ex s: Special protection for Zone 1	
ZONE 2 Flammable atmosphere not likely occur and if it occurs will exist only for a short time (less than 10 hours per year)	Ex n: Non incentive Ex p: Pressurization for Zone 2 Ex p1: Purging for Zone 2 Ex v: Ventilation for Zone 2 Ex s: Special protection for Zone 1	

GAS GROUPS & TEMPERATURE CLASSES

Gas Group	Common gas or vapour in this group	Temperature Class for this gas	Kinyun LED Lamp Ex Code
IIC	Carbon disulphide	T6	<p>Ex ia IIC T3 IP67 Gas Groups: IIC, IIB & IIA Temperature Classes: T1 ~ T3 It covers petrol, nature gas, LPG, Acetylene, Hydrogen, Ethanol and Ammonia. It meets requirement of firefighting services and rescues.</p>
	Acetylene	T2	
IIB	Hydrogen	T1	
	Ethylene	T2	
IIA	Carbon Monoxide	T1	
	Kerosene	T3	
	Ethanol, Butane	T2	
	Ammonia	T1	



Kinyun Australia

Tel: 02-9981 3899

Fax: 02-9981 3826

Email: info@kinyun.com.au

Web: www.kinyun.com.au

